MYeBOX-1500-4G

MYeBOX-1500-4G, Portable power analyzer with recording of quality events and transients

Code: M84433.

- > Communications: Wi-Fi | 4G
- > Transistor output: 2
- > Digital inputs: 2
- > No. of voltage measurement inputs: 5
- > Measuring Channels: 5
- > Class: According to Class A

Description

MYeBOX® is a range of portable analysers that can be configured from an app and/or a website to analyse and record electrical parameters, measure and record waveform transients and network quality parameters, as per the EN 50160 standard. The information is accessible remotely from the app and/or website. MYeBOX® measures and records electrical parameters in single-phase, two-phase or three-phase installations (with and without a neutral).

The app/website is connected to the device to display the measured data in real time, fully configure the device, start or stop the data recording, send the recorded data to the **MYeBOX®** Cloud platform, and even access the data from the memory to view it graphically or in table form. The remote connectivity lets you analyse the measured data from anywhere. The recorded data can also be sent to a data repository for further analysis in PowerVision Plus. The device can be configured locally using the capacitive keyboard and the on-screen menu options.

MYeBOX® 150 and MYeBOX® 1500 have the following features and functions:

- 4 voltage measurement inputs (U_1, U_2, U_3, U_n)
- 4 current measurement inputs (I_1, I_2, I_3, I_n)
- Measurement of the main electrical parameters
- Measurement of network quality parameters
- True RMS measurement (TRMS)
- Measurement of consumption and generation (4Q)
- $\circ~$ Voltage quality event log, according to EN~61000-4-30
- Transients log
- $\circ\;$ Recording of the wave shape associated with the quality events and transients
- Measurement according to EN 61000-4-30
- Power supply is independent of the measurement
- Recording of the wave shape for each recording period
- LCD Screen
- Capacitive keypad
- Micro-USB port to download data
- Automatic detection of clamps
- Identification of phases with colours
- Compatible with clamps with EEPROM
- Recording of system events (EVA)
- NTP synchronisation
- Sending of alarms via e-mail
- Wi-Fi communications (access point/terminal)

The MYeBOX® 1500 model also has:

Circutor

Creation date: 07/04/2024 - CIRCUTOR, SAU reserves the right to make technical changes or modify the content/images of this document without prior notice, in order to improve its reliability, functionality, design or for other reasons. It accepts no liability for any errors, inaccuracies or possible lack of information in this document.

MYeBOX-1500-4G

Portable power analyzer

Code: M84433.

- \circ 1 voltage measurement input U_{ref}
- 1 leakage current measurement input
- $\,\circ\,$ 2 transistor inputs to centralise impulses / tariff / state
- 2 transistor outputs for alarms
- 3G/4G communications

Application

MYeBOX can be used to:

- $\circ~$ Prepare complete studies of an electrical installation.
- Analyse consumption, load curves, disturbances in the installation's voltage, display wave shapes, harmonics study or flicker measurement, among other options.
- Perform audits and analyses remotely.

Circutor

MYeBOX-1500-4G

Portable power analyzer

Code: M84433.

Specifications

Autonomy	2 h (without 4G), 50 min (with 4G)
Battery type	Lithium (3,7 Vc.c.)
Capacity	3700 mAh
Load temperature	0 40 °C
Load time	6 h
C power supply	
Installation category	CAT II 300 V
Consumption	2228 VA
Frequency	4763 Hz
Nominal voltage	100240 Vc.a.(Adaptador de alimentación de c.a.)
owered by charger, adapter	
Output voltage	9 Vc.c.
Maximum power	20 W
Battery specification	
Capacity	220 mAh
Performance-guarantee	10 years
Туре	Lithium
Voltage	3 Vc.c.
nvironmental characteristics	
Protection class	IP 30
Relative humidity (without condensation)	595 %
Storage temperature	-20+60 °C
Working temperature	-10+50 °C
Aechanical characteristics	
Envelope	Self-extinguishing VO plastic
Standards	
Certifications	UL, CAN/CSA-C22.2 No. 61010-1, 3rd Edition, 2012-5, CE
Electrical safety, Maximum height (m)	2000
Standards	Recycling European Directive 2002/96/EC, EN 61326-1, UL 61010-1, 3rd Editior 2012-05-11, IEC 61010-1, 3rd Edition

Page 3 of 8

Page 4 of 8

×

MYeBOX-1500-4G

Portable power analyzer

Code: M84433.

,250 A ó 0,333 V
00 V (IEC)
ck protection class II (IEC 61010-1)
2 lines
-

MYeBOX-1500-4G

Portable power analyzer

Code: M84433.

Quantity	2
Туре	Opto MOSFET
Maximum current	90 mA
Maximum voltage	48 Vcc

Measurement accuracy

······,	
Current asymmetry (Ka)	Class A (IEC 61000-4-30)
Voltage asymmetry (Ka)	Class A (IEC 61000-4-30)
Current unbalance (Kd)	Class A (IEC 61000-4-30)
Voltage unbalance (Kd)	Class A (IEC 61000-4-30)
Frequency measurement	Class 0,1 (4565 Hz)
Phase current measurement	Class 0,2 (1200 % In) (IEC 61557-12)
Reactive energy measurement (kvarh)	Class 1 (IEC 62053-23)
Power factor measurement	Class 0,5 (IEC 61557-12)
Phase voltage measurement	Class 0.2 (101000 VF-N ~) (IEC 61557-12)
Pinst. Flicker	3 % (IEC 61000-4-15)
Pst Flicker	5 % (0,2 10Pst) (IEC 61000-4-15)

MYeBOX

Portable power analyzer with recording of quality events and transients

CODE	ТҮРЕ	Class	Communications	No. of voltage measurement inputs	Measuring current Channels	Measuring Channels	Transistor output	Digital inputs	Nr Sensors
M840230000A00	MYeBOX-150	Class A	Wi-Fi	4	4				
Portable analyzer l	kits with current sensors								
M844330000A00	MYeBOX-1500-4G		Wi-Fi 4G			5	2	2	
M8445B0000A00	MYeBOX-1500-4G + 3 FLEX-R45		Wi-Fi 4G			5	2	2	3 FLEX-R45
M8445C0000A00	MYeBOX-1500-4G + 4 FLEX-R45		Wi-Fi 4G			5	2	2	4 FLEX-R45
M8445D0000A00	MYeBOX-1500-4G + 3 FLEX-R80		Wi-Fi 4G			5	2	2	3 FLEX-R80
M8445E0000A00	MYeBOX-1500-4G + 4 FLEX-R80		Wi-Fi 4G			5	2	2	4 FLEX-R80
M844530000A00	MYeBOX-1500-4G + 3 CPG-100		Wi-Fi 4G			5	2	2	3 CPG-100
M844550000A00	MYeBOX-1500-4G + 3 CPRG-500		Wi-Fi 4G			5	2	2	3 CPRG-500
M84023.	MYeBOX-150	According to Class A	Wi-Fi	4	4				
484433.	MYeBOX-1500-4G		Wi-Fi 4G			5	2	2	
M8404B.	MYeBOX-150+3 FLEX-R45	According to Class A	Wi-Fi	4	4				3 FLEX-R45
M8445B.	MYeBOX-1500-4G + 3 FLEX-R45		Wi-Fi 4G			5	2	2	3 FLEX-R45
M8404C.	MYeBOX-150-4 FLEX-R45	According to Class A	Wi-Fi	4	4				4 FLEX-R45
48445C.	MYeBOX-1500-4G + 4 FLEX-R45		Wi-Fi 4G			5	2	2	4 FLEX-R45

Circutor

MYeBOX-1500-4G

Portable power analyzer

Code: M84433.

CODE	ТҮРЕ	Class	Communications	No. of voltage measurement inputs	Measuring current Channels	Measuring Channels	Transistor output	Digital inputs	Nr Sensors
M8404D.	MYeBOX-150-3 FLEX-R80	According to Class A	Wi-Fi	4	4				3 FLEX-R80
M8445D.	MYeBOX-1500-4G + 3 FLEX-R80		Wi-Fi 4G			5	2	2	3 FLEX-R80
M8404E.	MYeBOX-150-4 FLEX-R80	According to Class A	Wi-Fi	4	4				4 FLEX-R80
M8445E.	MYeBOX-1500-4G + 4 FLEX-R80		Wi-Fi 4G			5	2	2	4 FLEX-R80
M84043.	MYeBOX-150 + 3 CPG-100	According to Class A	Wi-Fi	4	4				3 CPG-100
M84453.	MYeBOX-1500-4G + 3 CPG-100		Wi-Fi 4G			5	2	2	3 CPG-100
M84045.	MYeBOX-150 + 3 CPRG-500	According to Class A	Wi-Fi	4	4				3 CPRG-500
M84455.	MYeBOX-1500-4G + 3 CPRG-500		Wi-Fi 4G			5	2	2	3 CPRG-500

Analyser with built-in SD memory and Cloud Includes voltage cables, alligator clips, USB cable, fastening strap, magnetic support, battery, power supply and carrying bag. Please contact us for other clamp or clamp length combinations



MYeBOX-1500-4G

Portable power analyzer

Code: M84433.

Connections

Circutor

MYeBOX-1500-4G


Portable power analyzer

Code: M84433.


ALIMENTACIÓN AUXILIAR ëBOX 150 ëBOX 1500 0 880X 150 6 6 C ëBOX 1500 0 **ÖÖÖÖ**ÖÇ <u>.</u> ÖÖÖ U2 U3 U1 п 12 13 L1 L2 L2 L3 L3 CARGA / LOAD N CARGA / LOAD N

Red trifásica a 4 hilos / 4-wire three-phase network

Red monofásica fase-neutro de 2 hilos 2-wire Single-phase network (Neutral)



Conexión de la corriente de fuga, lLeak Leakage current connection, lLeak



Circutor

Creation date: 07/04/2024 - CIRCUTOR, SAU reserves the right to make technical changes or modify the content/images of this document without prior notice, in order to improve its reliability, functionality, design or for other reasons. It accepts no liability for any errors, inaccuracies or possible lack of information in this document.

Page 8 of 8